



For Professionals... Since 1857®

450 Bond Street • Lincolnshire, IL 60069 • p.847.821.5500 • www.Kleintools.com

Certificate of Compliance

REG004485

Klein Tools, Inc. certifies that the below products meets the criteria & standards listed below. Testing was completed at a 3rd Party, A2LA ISO 17025:2017 Accredited Testing Laboratory specializing in rubber, plastic and latex. Additionally, Klein Tools also has an ISO 17025:2017 accredited Testing Laboratory and Quality Assurance Department that work together to monitor and ensure on-going product quality.

Model Numbers	Description
SPF50LOT15	Sunscreen Lotion, Broad Spectrum SPF 50
SPF50SPY55	Sunscreen Spray, Broad Spectrum SPF 50

Standards and Tests	Results	
ASTM D120: Standard Specification for Rubber Insulating Gloves	Gloves Conditioned* with SPF50LOT15	Gloves Conditioned* with SPF50SPY55
A-C Proof Test Section 18.4.2	Pass	Pass
A-C Breakdown Test Section 18.4.3	Pass	Pass
A-C Moisture Absorption/Proof Test Section 18.4.4	Pass	Pass

* Class 2, Dielectric Rubber Gloves meeting ASTM D120 specifications were conditioned by:

1. Applying a liberal amount of sunscreen (SPF50LOT15 and SPF50SPY55) to the outside surfaces
2. Wiping off and allowing them to stand for 4 hours
3. Washing with mild soap and warm water
4. Repeating steps 1-3, once per day for three days.

Justin Zirbes
Manager, Compliance Engineering and Product Support

6 / 6 / 2025

Date