


USA: 815 Chestnut St., No. Andover, MA 01845-6098; www.watts.com
 Canada: 5435 North Service Rd., Burlington, ONT, L7L 5H7; www.wattscanada.ca

Water Safety & Flow Control Products



EDP No.	Kit No.	Size
0888555	RKSD2T	1/4" - 3/8"
		8 - 10 mm

SD2 Total Repair Kit

Installation

Limited Warranty: Watts Regulator Co. (the "Company") warrants each product to be free from defects in material and workmanship under normal usage for a period of one year from the date of original shipment. In the event of such defects within the warranty period, the Company will, at its option, replace or recondition the product without charge.

THE WARRANTY SET FORTH HEREIN IS GIVEN EXPRESSLY AND IS THE ONLY WARRANTY GIVEN BY THE COMPANY WITH RESPECT TO THE PRODUCT. THE COMPANY MAKES NO OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

The remedy described in the first paragraph of this warranty shall constitute the sole and exclusive remedy for breach of warranty, and the Company shall not be responsible for any incidental, special or consequential damages, including without limitation, lost profits or the cost of repairing or replacing other property which is damaged if this product does not work properly, or other costs resulting from labor charges, delays, vandalism, negligence, fouling caused by foreign material, damage from adverse water conditions, chemical, or any other circumstances over which the Company has no control. This warranty shall be invalidated by any abuse, misuse, misapplication, improper installation or improper maintenance or alteration of the product.

Some States do not allow limitations on how long an implied warranty lasts, and some States do not allow the exclusion or limitation of incidental or consequential damages. Therefore the above limitations may not apply to you. This Limited Warranty gives you specific legal rights, and you may have other rights that vary from State to State. You should consult applicable state laws to determine your rights. **SO FAR AS IS CONSISTENT WITH APPLICABLE STATE LAW, ANY IMPLIED WARRANTIES THAT MAY NOT BE DISCLAIMED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, ARE LIMITED IN DURATION TO ONE YEAR FROM THE DATE OF ORIGINAL SHIPMENT.**

CALIFORNIA PROPOSITION 65 WARNING
 WARNING: This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm.
 (California law requires this warning to be given to customers in the State of California.)
 For more information: www.watts.com/prop65

Series SD2

Backflow Preventers for Carbonated Beverage Machines

Sizes: 1/4" - 3/8" (8 - 10mm)

Installation Instructions

The Watts SD2 is a dual check designed for the protection of the water supply from carbon dioxide gas and carbonated water. These substances can flow from post-mix beverage systems and are very acidic. If the acidic water comes in contact with copper tubing or copper pipe, it will cause the leaching of copper salts into the water supply. The dissolved copper if ingested can cause nausea, abdominal pain, and in some cases vomiting. The SD2 prevents the reverse flow of potentially contaminated water back into the potable water supply due to back pressure backflow and is used for continuous or intermittent pressure conditions.

Installation

Before installing, flush out pipe lines to remove scale and other foreign matter. The valve can be installed horizontally or vertically (flow up or down). Install the valve in the line with the arrow on the valve body pointing in the direction of flow. The valve should be installed such that the valve is accessible for service and maintenance.

Important

The device should not be installed inside a wall or in a concealed location. Copper tubing shall not be used on the downstream side of the backflow preventer.



Applications

The Watts SD2 is recommended for use on Post-Mix Carbonated Beverage Equipment and dispensing equipment for tea and coffee.

Maintenance

Annual inspection is required of the backflow preventer to insure proper operation of the device. It is also recommended that a strainer be installed upstream of the backflow preventer.

Temperature and Pressure

Maximum Pressure - 200psi (13.8 bar). Maximum Temperature - 110°F (43°C).

Repair Kit

Kit consists of First and Second Check assemblies complete.





Series SD2 Backflow Preventers for Carbonated Beverage Machines

Sizes: 1/4" - 3/8" (8 - 10mm)

Installation Instructions

The Watts SD2 is a dual check designed for the protection of the water supply from carbon dioxide gas and carbonated water. These substances can flow from post-mix beverage systems and are very acidic. If the acidic water comes in contact with copper tubing or copper pipe, it will cause the leaching of copper salts into the water supply. The dissolved copper if ingested can cause nausea, abdominal pain, and in some cases vomiting. The SD2 prevents the reverse flow of potentially contaminated water back into the potable water supply due to back pressure backflow and is used for continuous or intermittent pressure conditions.

Installation

Before installing, flush out pipe lines to remove scale and other foreign matter. The valve can be installed horizontally or vertically (flow up or down). Install the valve in the line with the arrow on the valve body pointing in the direction of flow. The valve should be installed such that the valve is accessible for service and maintenance.

Important

The device should not be installed inside a wall or in a concealed location. Copper tubing shall not be used on the downstream side of the backflow preventer.



Applications

The Watts SD2 is recommended for use on Post-Mix Carbonated Beverage Equipment and dispensing equipment for tea and coffee.

Maintenance

Annual inspection is required of the backflow preventer to insure proper operation of the device. It is also recommended that a strainer be installed upstream of the backflow preventer.

Temperature and Pressure

Maximum Pressure - 200psi (13.8 bar). Maximum Temperature - 110°F (43°C).

Repair Kit


Kit consists of First and Second Check assemblies complete.

IS-SD2

SD2 Total Repair Kit

EDP No.	Kit No.	Size	
		in.	mm
0888555	RKSD2T	1/4 - 3/8	8 - 10

Installation



CALIFORNIA PROPOSITION 65 WARNING

WARNING: This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm. (California law requires this warning to be given to customers in the State of California.)

For more information: www.watts.com/prop65

Limited Warranty: Watts Regulator Co. (the "Company") warrants each product to be free from defects in material and workmanship under normal usage for a period of one year from the date of original shipment. In the event of such defects within the warranty period, the Company will, at its option, replace or recondition the product without charge.

THE WARRANTY SET FORTH HEREIN IS GIVEN EXPRESSLY AND IS THE ONLY WARRANTY GIVEN BY THE COMPANY WITH RESPECT TO THE PRODUCT. THE COMPANY MAKES NO OTHER WARRANTIES, EXPRESS OR IMPLIED. THE COMPANY HEREBY SPECIFICALLY DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

The remedy described in the first paragraph of this warranty shall constitute the sole and exclusive remedy for breach of warranty, and the Company shall not be responsible for any incidental, special or consequential damages, including without limitation, lost profits or the cost of repairing or replacing other property which is damaged if this product does not work properly, other costs resulting from labor charges, delays, vandalism, negligence, fouling caused by foreign material, damage from adverse water conditions, chemical, or any other circumstances over which the Company has no control. This warranty shall be invalidated by any abuse, misuse, misapplication, improper installation or improper maintenance or alteration of the product.

Some States do not allow limitations on how long an implied warranty lasts, and some States do not allow the exclusion or limitation of incidental or consequential damages. Therefore the above limitations may not apply to you. This Limited Warranty gives you specific legal rights, and you may have other rights that vary from State to State. You should consult applicable state laws to determine your rights. **SO FAR AS IS CONSISTENT WITH APPLICABLE STATE LAW, ANY IMPLIED WARRANTIES THAT MAY NOT BE DISCLAIMED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, ARE LIMITED IN DURATION TO ONE YEAR FROM THE DATE OF ORIGINAL SHIPMENT.**



Water Safety & Flow Control Products



USA: 815 Chestnut St., No. Andover, MA 01845-6098; www.watts.com

Canada: 5435 North Service Rd., Burlington, ONT. L7L 5H7; www.wattscanada.ca