

PRODUCT DATA SHEET

Controlled Document - Engineering Drive

1530 Shields Drive Waukegan, IL 60085 Toll-Free (800) 323-9355 Fax: (847) 689-1192

PART NUMBER: 60126

DESCRIPTION: 16/2 STRANDED TYPE SPT-2

CONSTRUCTION: This cable consists of two bare copper conductors laid flat with integral insulation and jacket.

APPROVALS: UL Standard 62, CSA 22.2 No. 49, NEC Article 400.

APPLICATION: 300V Flexible Cable

Construction Parameters:

Conductor 16 AWG Bare Copper

Stranding 26/30
Insulation Material PVC
Insulation Thickness 0.048" Nom.

Insulated Conductor Diameter 0.155" x 0.303" Nom.

Number of Conductors

Approximate Cable Weight 36.0 Lbs/1M' Nom.

Flame Rating UL/CSA Horizontal Flame Test

Electrical Properties:

Temperature Rating -20°C to 60°C
Operating Voltage 300 V RMS Max.
DC Resistance per Conductor @ 20°C 4.00 Ohms/1M' Nom.

Insulation/Jacket Colors

Black, Brown, White (Other colors available for mimimun order - consult factory)

Legend (Indent Print)

E54864 * 16-2 SPT-2 (UL) -- CSA LL39753 * 16-2 SPT-2 60C FT2

This product complies with European Directive 2002/95/EC (RoHS)

On special orders, the customer will accept all factory lengths and +/- 10 percent of total order requested.

The information presented here is, to the best of our knowledge, true and accurate. Since conditions of use are beyond Coleman Cable's control all product data presented is for informational purposes only and does not create a binding obligation or liability on Coleman Cable or confer any rights on any customer. The sale of products(s) is conditioned upon acceptance of a purchase order subject to Coleman Cable's standard terms and conditions contained therein, including without limitation Coleman Cable's standard warranty. Coleman Cable disclaims all liability in connection with the use of information contained herein or otherwise.

This specification is proprietary intellectual property of Coleman Cable. Any information contained herein shall not be disclosed to any party without written consent of Coleman Cable.

Customer Name	
Customer Approval	

Specification Issue Date: November 26, 2008