SPECIFICATION SHEET

BRSAN

MODEL XB50 VENTILATION FAN



UltraGreen[™] Energy Saving DC Motor

- DC motor for efficiency well beyond ENERGY STAR[®] requirements.
- Can be used to comply with ASHRAE 62.2, LEED, ENERGY STAR® for Homes and CA Title 24.

UltraSilent[™] Sound Technology

- HVI certified, best-achievable <0.3 Sone level provides nearly silent operation for a relaxing environment.
- State-of-the-art blower and duct outlet design smooths airflow.
- High tech DC motor designed for nearly silent operation.

UltraSmart[™] Control Technology

• Powerful operation maintained over a wide range of realworld installations (CFM ratings maintained through at least 0.25" static pressure).

UltraQuick[™] Installation Technology


- Unique telescoping mounting frame fits through retrofit drywall opening to allow easy installation from the room side. No attic access needed!
- Captive screws allow for easy new construction installation.
- Mounting frame positioning tabs provide easy vertical positioning for new construction.
- Easy to insert and remove snap-in housing. No screws required!
- Easy to insert and remove snap-in blower.
- Inside or outside duct connector and knockout plate mounting provides flexibility for new construction or retrofit.

U.L. Listed for use over bathtubs and showers when connected to a GFCI protected branch circuit (ceiling mount only).

3-year warranty.

Broan-NuTone LLC Hartford, Wisconsin www.broan.com 800-558-1711 REFERENCE QTY. REMARKS Project Location Architect Engineer Contractor Submitted by Date

DIMENSIONS (Inches)





PERFORMANCE SPECIFICATIONS MODEL XB50 VENTILATION FAN

HVI PERFORMANCE

[®] 2100

CERTIFIED

4" Duct					6" Duct				
0.1 P	0.1 Ps - Static Pressure (inH2O)				0.1 Ps - Static Pressure (inH2O)			0.25 Ps	
-	Sound (Sones)		Efficacy (CFM/Watt)	-	-	Sound (Sones)		Efficacy (CFM/Watt)	Airflow (CFM)
50	< 0.3	5.1	9.8	50	50	< 0.3	4.9	11.8	49



Volts	Hz	Amps	Shipping Weight (lbs.)
120	60	0.1	12.5



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in a state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.

