


REDUCING BASE SUPPORT ELBOW

☐ **FIG. 7050RF** – Grooved x 150# Flanged (GxF)



**FIGURE 7050 RF REDUCING
BASE SUPPORT ELBOW**

Nominal Size	Grooved End O.D.	Center to End	H	B Dia. Threaded	Approx. Wt. Ea. GxF
In./DN(mm)	In./mm	In./mm	In./mm	NPSC	Lbs./Kg
6 x 4 150 x 100	6.625 168.3	12 305	2½ 64	1½ 38	38.5 17.5
6 x 5 150 x 125	6.625 168.3	12½ 318	2½ 64	1½ 38	45.4 20.6
8 x 5 200 x 125	8.625 219.1	16 406	3 76	1½ 38	65.5 29.7
8 x 6 200 x 150	8.625 219.1	16 406	3 76	1½ 38	73 33.1
10 x 6 250 x 150	10.750 273.1	19 483	3½ 89	1½ 38	100 45.4
10 x 8 250 x 200	10.750 273.1	19 483	3½ 89	1½ 38	127 57.6
12 x 8 300 x 200	12.750 323.9	22 559	4 102	1½ 38	155 70.3
12 x 10 300 x 250	12.750 323.9	22 559	4 102	1½ 38	186 84.4

This product is not UL/ULC Listed or FM Approved.




For Listings/Approval Details and Limitations, visit our website at www.anvilintl.com or contact an Anvil® Sales Representative.

GROOVED FLANGE NIPPLES

☐ **FIG. 7084** – Groove x Class 150 Flange Nipple

☐ **FIG. 7085** – Groove x Class 300 Flange Nipple



**FIGURE 7084
GROOVE X CLASS 150
FLANGE NIPPLE**

Nominal Size	O.D.	End to End	Approx. Wt. Ea.
In./DN(mm)	In./mm	In./mm	Lbs./Kg
1 25	1.315 33.4	3 76	2.5 1.1
1¼ 32	1.660 42.2	4 102	3.8 1.7
1½ 40	1.900 48.3	4 102	4.1 1.9
2 50	2.375 60.3	4 102	6.0 2.7
2½ 65	2.875 73.0	4 102	9.2 4.2
3 80	3.500 88.9	4 102	10.4 4.7
3½ 90	4.000 101.6	4 102	14.0 6.4
4 100	4.500 114.3	6 152	19.1 8.7
5 125	5.563 141.3	6 152	23.0 10.4
6 150	6.625 168.3	6 152	29.5 13.4
8 200	8.625 219.1	6 152	43.5 19.7
10 250	10.750 273.1	8 203	68.2 30.9
12 300	12.750 323.9	8 203	96.1 43.6
14 350	14.000 355.6	* *	* *
16 400	16.000 406.4	* *	* *
18 450	18.000 457.2	* *	* *
20 500	20.000 508.0	* *	* *
24 600	24.000 609.6	* *	* *

* Contact an Anvil Representative for dimensions & weights.

**FIGURE 7085
GROOVE X CLASS 300
FLANGE NIPPLE**

End to End	Approx. Wt. Ea.
In./mm	Lbs./Kg
3 76	3.6 1.6
4 102	4.6 2.1
4 102	7.1 3.2
4 102	8.2 3.7
4 102	11.9 5.4
4 102	15.5 7.0
4 102	21.0 9.5
6 152	28.0 12.7
6 152	35.0 15.9
6 152	50.0 22.7
6 152	72.0 32.7
8 203	* *
8 203	* *
* *	* *
* *	* *
* *	* *
* *	* *
* *	* *

This product is not UL/ULC Listed or FM Approved.

PROJECT INFORMATION

Project:	☐ Approved
Address:	☐ Approved as noted
Contractor:	☐ Not approved
Engineer:	Remarks:
Submittal Date:	
Notes 1:	
Notes 2:	