



Important Recall Notice

March 21, 2018

KID PI2010

Dear Valued Customer:

Today, Kidde, in conjunction with the U.S. Consumer Product Safety Commission (CPSC) announced a voluntary recall to replace certain Kidde dual sensor smoke alarms. To view the release, please visit www.kidde.com and click on "Product Safety Recall Notice."

As communicated to you in a stop ship/stop sale notice, dated January 26, 2018, Kidde has determined that a yellow protective cap may have been left on one of the two smoke sensors during the manufacturing process, which compromises the alarm's ability to detect smoke. As a result, we have voluntarily initiated a recall of the affected units.

This recall involves two models of Kidde dual sensor smoke alarms with manufacture dates between September 10, 2016 and October 13, 2017. The potentially affected models are PI2010 and PI9010.

If you receive consumer inquiries, please immediately direct them to visit www.Kidde.com or call Kidde (toll-free) at 1-833-551-7739 from 8:30 a.m. to 5 p.m. ET Monday through Friday and Saturday and Sunday from 9 a.m. to 3 p.m. ET to determine whether their smoke alarms are affected. .

Based on our stop sale notice, you should have already segregated and discontinued selling the affected alarms. If not, please do so immediately. All affected inventory should be returned to Kidde and a credit will be issued. The attached cross-reference list contains SKU numbers of affected units as well as their replacements, where applicable.

Model	Affected Product		New Product / Replacement SKU	
	SKU	UPC	SKU	UPC
PI2010	21007915	0-47871-07915-5	21007915-N	0-47871-27130-6
	21026061	0-47871-26061-4	21026061-N	0-47871-26161-1
	21027130	0-47871-07915-5	21027130-N	0-47871-27130-6
PI9010	21007385	0-47871-42007-0	21007385-N	0-47871-42017-9
	21009410	0-47871-09410-3	No Replacement SKU	
	44200702	0-47871-42007-0	44200702-N	0-47871-42017-9
	21026062	0-47871-26062-1	21026062-N	0-47871-26162-8
	21026400	0-47871-09594-0	No Replacement SKU	
	21027166	0-47871-09410-3	21027166-N	0-47871-27166-5
	21027563	0-47871-09594-0	21027563-N	0-47871-27563-2

If you have questions, please do not hesitate to contact your Regional Sales Manager.

We apologize for any inconvenience this may cause and thank you for your cooperation in this matter.

Sincerely,

Alex Houston
Vice President & General Manager
UTC Climate, Controls & Security
Fire & Security Products Americas