# **CAST IRON THREADED FITTINGS**



### Class 250 (Extra Heavy)

FIGURE 425	Size		A		В	)	Unit Weight		
Tee	31	<b>Z</b> E	P	1		)	Black		
	NPS	DN	in	mm	in	mm	lbs	kg	
	1/4	8	<sup>5</sup> /8	16	<sup>15</sup> / <sub>16</sub>	24	0.47	0.21	
	3/8	10	<sup>11</sup> / <sub>16</sub>	17	<b>1</b> <sup>1</sup> / <sub>16</sub>	27	0.70	0.32	
	1/2	15	3/4	19	1 <sup>1</sup> / <sub>4</sub>	32	1.20	0.54	
	3/4	20	7/8	22	<b>1</b> <sup>7</sup> / <sub>16</sub>	37	1.57	0.71	
	1	25	1	25	1 <sup>5</sup> /8	41	2.43	1.10	
	1 <sup>1</sup> / <sub>4</sub>	32	<b>1</b> <sup>3</sup> / <sub>16</sub>	30	<b>1</b> <sup>15</sup> / <sub>16</sub>	49	3.94	1.79	
-B	1 <sup>1</sup> / <sub>2</sub>	40	<b>1</b> <sup>7</sup> / <sub>16</sub>	37	21/8	54	5.31	2.41	
A → A → B	2	50	1 <sup>3</sup> / <sub>4</sub>	44	21/2	64	9.01	4.09	
	21/2	65	<b>1</b> <sup>15</sup> / <sub>16</sub>	49	2 <sup>15</sup> / <sub>16</sub>	75	14.23	6.45	
	3	80	2 <sup>5</sup> / <sub>16</sub>	59	33/8	86	20.95	9.50	
	4	100	2 <sup>15</sup> /16	75	4 <sup>1</sup> / <sub>8</sub>	105	33.98	15.41	

FIGURE 426	Size					A, B		C		D.E.		F		Unit Weight		
Reducing Tee			31	Ze			Α,	D			D, E		F		Black	
	NPS	DN	NPS	DN	NPS	DN	in	mm	in	mm	in	mm	in	mm	lbs	kg
	3/4	20	3/4	20	1/2	15	3/4	19	7/8	22	<b>1</b> <sup>5</sup> / <sub>16</sub>	33	1 <sup>3</sup> /8	35	1.37	0.62
		25	1	25	1/2	15	3/4	19	1	25	1 <sup>3</sup> /8	35	1 <sup>1</sup> / <sub>2</sub>	38	2.03	0.92
	1				3/4	20	7/8	22	1	25	1 <sup>1</sup> / <sub>2</sub>	38	<b>1</b> <sup>9</sup> / <sub>16</sub>	40	2.19	0.99
	1 <sup>1</sup> / <sub>4</sub>	32	11/4	32	3/4	20	<sup>15</sup> / <sub>16</sub>	24	1 <sup>1</sup> /8	29	1 <sup>5</sup> /8	41	<b>1</b> <sup>11</sup> / <sub>16</sub>	43	3.21	1.46
		32			1	25	<b>1</b> <sup>1</sup> / <sub>16</sub>	27	<b>1</b> <sup>3</sup> / <sub>16</sub>	30	1 <sup>3</sup> / <sub>4</sub>	44	<b>1</b> <sup>13</sup> / <sub>16</sub>	47	3.49	1.58
	11/2	40	11/2		3/4	20	1	25	1 <sup>1</sup> / <sub>4</sub>	32	<b>1</b> <sup>11</sup> / <sub>16</sub>	43	1 <sup>7</sup> /8	48	4.02	1.82
A B F				40	1	25	<b>1</b> <sup>1</sup> /8	29	1 <sup>5</sup> / <sub>16</sub>	33	<b>1</b> <sup>13</sup> / <sub>16</sub>	47	1 <sup>15</sup> / <sub>16</sub>	49	4.26	1.93
					1 <sup>1</sup> / <sub>4</sub>	32	<b>1</b> <sup>5</sup> / <sub>16</sub>	33	1 <sup>3</sup> /8	35	2	51	2 <sup>1</sup> / <sub>16</sub>	52	4.98	2.26
	2				3/4	20	1 <sup>1</sup> /8	29	<b>1</b> <sup>7</sup> / <sub>16</sub>	37	1 <sup>7</sup> /8	48	2	51	6.24	2.83
		50	2	50	1	25	1 <sup>1</sup> / <sub>4</sub>	32	1 <sup>1</sup> / <sub>2</sub>	38	2	51	21/8	54	6.57	2.98
					1 <sup>1</sup> / <sub>4</sub>	32	1 <sup>3</sup> /8	35	1 <sup>9</sup> / <sub>16</sub>	40	2 <sup>3</sup> / <sub>16</sub>	56	2 <sup>1</sup> / <sub>4</sub>	57	7.11	3.22
					1 <sup>1</sup> / <sub>2</sub>	40	<b>1</b> <sup>1</sup> / <sub>2</sub>	38	1 <sup>5</sup> /8	41	<b>2</b> <sup>5</sup> / <sub>16</sub>	59	2 <sup>5</sup> / <sub>16</sub>	59	7.69	3.49

 $\textbf{Note:} \ \mathsf{See} \ \mathsf{following} \ \mathsf{page} \ \mathsf{for} \ \mathsf{pressure-temperature} \ \mathsf{ratings}.$ 

PROJECT INFORMATION	APPROVAL STAMP				
Project:	☐ Approved				
Address:	Approved as noted				
Contractor:	☐ Not approved				
Engineer:	Remarks:				
Submittal Date:					
Notes 1:					
Notes 2:					

#### **CAST IRON THREADED FITTINGS**





Anvil standard and extra heavy cast iron threaded fittings are manufactured in accordance with ASME B16.4. Plugs and bushings are manufactured in accordance with ASME B16.14.

**NOTE:** Figure 367 Concentric Reducers do not meet the overall length requirement of ASME B16.4. All other dimensions are in compliance.





For Listings/Approval Details and Limitations, visit our website at www.anvilintl.com or contact an Anvil Sales Representative.

Cast Iron Threaded Fittings									
Pressure - Temperature Ratings									
Pressure									
Temperature Class 125 Class 250									
(°F)	(°C)	psi	bar	psi	bar				
-20° to 150°	-28.9 to 65.6	175	12.1	400	27.6				
200°	93.3	165	11.4	370	25.5				
250°	121.1	150	10.3	340	23.4				
300°	148.9	140	9.7	310	21.4				
350°	176.7	125	8.6	300	20.7				
400°	204.4	_	_	250	17.2				

Standards and Specifications										
Dimensions Material Galvanizing* Thread Pressure Rating										
CAST IRON THREADED FITTINGS										
Class 125	ASME B16.4	ASTM A-126 (A)	ASTM A-153	ASME B1.20.1	ASME B16.4					
Class 250	ASME B16.4	ASTM A-126 (A)	ASTM A-153	ASME B1.20.1	ASME B16.4					
CAST IRON PLUGS AND BUSHINGS										
	ASME B16.14	ASTM A- 126 (A)	ASTM A-153	ASME B1.20.1	ASME B16.14					

<sup>\*</sup> ASTM B 633. Type I, SC 4, may be supplied as alternate zinc coating per applicable ASME B16 product standard.

#### **CAST IRON THREADED FITTINGS**



# **General Assembly of Threaded Fittings**

- 1) Inspect both male and female components prior to assembly.
  - Threads should be free from mechanical damage, dirt, chips and excess cutting oil.
  - Clean or replace components as necessary.
- 2) Application of thread sealant
  - Use a thread sealant that is fast drying, sets-up to a semi hard condition and is vibration resistant. Alternately, an anaerobic sealant may be utilized.
  - Thoroughly mix the thread sealant prior to application.
  - Apply a thick even coat to the male threads only. Best application is achieved with a brush stiff enough to force sealant down
    to the root of the threads.
- 3) Joint Makeup
  - For sizes up to and including 2" pipe, wrench tight makeup is considered three full turns past handtight. Handtight engagement for 1/2" through 2" thread varies from 41/2 turns to 5 turns.
  - For  $2^{1}/2^{"}$  through 4" sizes, wrench tight makeup is considered two full turns past handtight. Handtight engagement for  $2^{1}/2^{"}$  through 4" thread varies from  $5^{1}/2$  turns to  $6^{3}/4$  turns.