## **STRUCTURAL ATTACHMENTS**



Size Range: 3/8" through  $3^{1}/2$ " Material: Carbon steel

Finish: 🔲 Plain or 🛄 Hot-Dip Galvanized

ANSI/MSS SP-69 and MSS SP-58 (Type 22).

attachment in an inverted position to the beam.

considerable and rod sizes are large.

## Welded Beam Attachment

Approvals: Complies with Federal Specification A-A-1192A (Type 22), WW-H-171-E (Type 22), Installation: If flexibility at the beam is desired, use with bolt and eye rod Fig. 278 or with weldless eye nut Fig. 290. If vertical adjustment is desired, use with threaded rod and nut and weld the

## Features:

- Will accommodate very heavy loads and rod sizes through  $3^{1/2}$ ".
- Can be installed so as to provide for either flexibility or for vertical adjustment. •

Service: Recommended for attachment to bottom of beams, especially where loads are


Versatility affords economical stocking and erection.

Maximum Temperature: Plain 750° F, Galvanized 450° F

Beam size need not be considered.

Ordering: Specify rod size, figure number, name and finish. Sizes 1" and smaller are typically supplied with a bolt and nut. Sizes  $1^{1}/4^{"}$  and larger are typically supplied with a pin and cotters.


		Field Weld
Ø		ð
2" P.a.d. Dia	and Larger are	- T



 $1^3 \not \!\!\!/_4$  " Rod Dia. and Smaller are Formed using Bolt or Pin and Eye Rod.

Attachment in Inverted Position.

Using Hanger Rod with



1<sup>1</sup>/<sub>4</sub>" Rod Dia. and Smaller Only.

FIG: 66: LOAD (LBS) • WEIGHT (LBS) • DIMENSIONS (IN)												
Rod Size A	Pin or Bolt Size	Max Load		Weight		Rod Take Out						
		650° F	750° F	Without Bolt and Nut	With Bolt and Nut	E	E'	B	Н	R	S	Т
3/8	<sup>1</sup> / <sub>2</sub> x 2 <sup>1</sup> / <sub>2</sub>	730	572		1.2	11 %	2	2	<sup>9</sup> /16		11/4	1/4
1/2	5∕% x 2¹∕₂	1,350	1,057	0.96	1.3				11/16	7/8		
5/8	<sup>3</sup> / <sub>4</sub> x 2 <sup>3</sup> / <sub>4</sub>	2,160	1,692		1.6	1 <sup>3</sup> ⁄4			<sup>13</sup> / <sub>16</sub>			
3⁄4	<sup>7</sup> ∕8 x 4	3,230	2,530	1.9	2.8	1		<b>2</b> <sup>1</sup> / <sub>2</sub>	15/16	11/8	11%	3⁄8
7/8	1 x 4	4,480	3,508	2.5	3.9	25/8			<b>1</b> ½	11/4	2	
1	1½x 5	5,900	4,620	4.3	6.3	23/4	3	3	11/4	<b>1</b> ½	01/	1/2
11/4	1¾ x 5¾	9,500	7,440	8.1	10.2	27/8		4	11/2	2	<b>2</b> <sup>1</sup> / <sub>2</sub>	5/8
11/2	15% x 6	13,800	10,807	-	19.0	- 1	4	- 5	13⁄4	<b>2</b> <sup>1</sup> / <sub>2</sub>	3 3 <sup>3</sup> ⁄4	3⁄4
1¾	1 <sup>7</sup> / <sub>8</sub> x 6 <sup>7</sup> / <sub>8</sub>	18,600	14,566	-	24.2	-			2	2 <sup>3</sup> /4		
2	2 <sup>1</sup> / <sub>4</sub> x 6 <sup>7</sup> / <sub>8</sub>	24,600	19,265	_	30.6	-	5		2 <sup>3</sup> / <sub>8</sub>	3 <sup>1</sup> /4	01/	1/2
2 <sup>1</sup> /4	2 <sup>1</sup> / <sub>2</sub> x 7 <sup>3</sup> / <sub>8</sub>	32,300	25,295	_	36.8	_	5 <sup>3</sup> ⁄ <sub>4</sub>		<b>2</b> <sup>5</sup> / <sub>8</sub>	<b>3</b> <sup>1</sup> / <sub>2</sub>	<b>3</b> <sup>1</sup> / <sub>2</sub>	5/8
2 <sup>1</sup> / <sub>2</sub>	2 <sup>3</sup> / <sub>4</sub> x 7 <sup>5</sup> / <sub>8</sub>	39,800	31,169	_	39.7	-		6	27/8	<b>3</b> <sup>3</sup> ⁄4	33/4	
2 <sup>3</sup> /4	3 x 7	49,400	38,687	_	40.8	-			31/8			
3	3¼ x 7	60,100	47,066	_	46.7	-		_	<b>3</b> <sup>3</sup> / <sub>8</sub>	4		
31/4	3 <sup>1</sup> / <sub>2</sub> x 7 <sup>3</sup> / <sub>4</sub>	71,900	56,307	_	62.1	-	7 7 <sup>1</sup> / <sub>2</sub>	- 7	35/8	4 <sup>1</sup> / <sub>2</sub>	<b>4</b> <sup>1</sup> / <sub>4</sub>	3⁄4
<b>3</b> <sup>1</sup> / <sub>2</sub>	3 <sup>3</sup> / <sub>4</sub> x 7 <sup>3</sup> / <sub>4</sub>	84,700	66,331	_	72.4	_		8	37/8			

PROJECT INFORMATION	APPROVAL STAMP
Project:	Approved
Address:	Approved as noted
Contractor:	🗋 Not approved
Engineer:	Remarks:
Submittal Date:	
Notes 1:	
Notes 2:	
DL 1 15	



