



ETL Listed  
 ETL Control # 3107144  
 2 Hour Fire Wall Rating  
 Conforms to UL Std. 514C  
 $\frac{1}{2}$ "  $\frac{3}{4}$ " and 1" concentric knockouts (one on each side of the wall, except on stud wall).  
 38 Cubic Inch Nonmetallic ENT Switch/Outlet Box  
 Mounts with flange along the side of the box



**CANTEX**  
 INC.  
 Fort Worth, TEXAS

38 Cubic Inch Two Gang ENT  
 Switch/Outlet Box

Drawn By: D. Gwinn

Date: 3/20/18

Ref. EN38DB