SP Units 3"

Full Submersible Pitless Units

Submittal Data



SP Unit

Job or Customer _____

Engineer _____

Contractor _____

Submitted by _____ Date _____

Approved by _____ Date _____



WC Cap

Purchase Order Number: _____

Date Required _____

Technical Data

SP301	3" casing size and 1' bury depth with 1-1/4" drop and discharge pipe size
SP302	3" casing size and 2' bury depth with 1-1/4" drop and discharge pipe size
SP303	3" casing size and 3' bury depth with 1-1/4" drop and discharge pipe size
SP304	3" casing size and 4' bury depth with 1-1/4" drop and discharge pipe size
SP305	3" casing size and 5' bury depth with 1-1/4" drop and discharge pipe size
SP306	3" casing size and 6' bury depth with 1-1/4" drop and discharge pipe size
SP307	3" casing size and 7' bury depth with 1-1/4" drop and discharge pipe size
SP308	3" casing size and 8' bury depth with 1-1/4" drop and discharge pipe size

Each unit includes bury depth plus 1' of casing

Example: 4' bury depth would be 5' from discharge to top of casing. A sanitary watertight cap must be ordered to complete the installation. Add WC to part number for complete unit with cap.

Example: SP304WC

Material Specifications

	Unit Casing Pipe	Schedule 40 Black Pipe
	Discharge Fitting	304 Stainless Steel
#312	Sealing Elbow	304 Stainless Steel
	Adjusting Rod and Slide Plates	Steel
	Pull Pipe	Schedule 80 Galvanized Pipe
#309	Adjustment Nut	Stainless Steel
#314	Support Plate	Galvanized Steel
#413	Pull Coupling	Galvanized
#315	Lock Nut	Galvanized

315 Flindt Drive
P.O. Box 392
Storm Lake, Iowa
50588-0392 U.S.A.

Main # (712) 732-2760
U.S. & Canada # (800) 831-6962
Fax # (712) 732-4401
U.S. Fax # (800) ANY FLOW
www.merrillmfg.com