

Sloan® Bedpan Washer Model BPW-1100 Flushometer



Description

Sloan® Bedpan Washer Water Closet Flushometer for floor mounted or wall hung top spud bowls. Installation meets ADA height requirements.

Flush Cycle

- Model BPW 1100 Water Saver (3.5 gpf/13.2 Lpf)
- Model BPW-1100-1.6 Low Consumption (1.6 gpf/6.0 Lpf)

Variations

- DFB** Dual Filtered Fixed Bypass Diaphragm
- TP** Trap Primer
- SG** SaniGuard® Antimicrobial Handle and Spray Arm*
- HL-3** 3" Metal Oscillating Push Button on Front of Valve
- YJ** Split Ring Pipe Support Variation
- YI** Two Wall Bumpers (for open front seat without cover)

Specifications

Quiet, Exposed, Diaphragm Type, Chrome Plated Closet Flushometer with the following features:

- High Chloramine Resistant PERMEX® Synthetic Rubber Diaphragm with Linear Filtered Bypass and Vortex Cleansing Action™
- ADA Compliant Metal Oscillating Non-Hold-Open Handle with Triple Seal Handle Packing
- 1" I.P.S. Screwdriver Bak-Chek® Angle Stop
- Vandal Resistant Stop Cap
- Adjustable Tailpiece
- Vacuum Breaker with Flush Connection
- Spud Coupling and Spud Flange for 1½" Top Spud
- Sweat Solder Adapter with Cover Tube and Cast Wall Flange
- High Copper, Low Zinc Brass Castings for Dezincification Resistance
- Non-Hold-Open Handle and No External Volume Adjustment to Ensure Water Conservation
- Low Consumption flush accuracy
- Handle Packing, Stop Seat and Vacuum Breaker Molded from PERMEX® Rubber Compound for Chloramine Resistance

Bedpan Washer Diverter Assembly with the following features:


- Solid One-piece Body Construction
- Solid Brass Spray Arm
- Counter Balanced Pivot Assembly
- Diverter Valve Wall Support

Valve Body, Cover, Tailpiece and Control Stop shall be in conformance with ASTM Alloy Classification for Semi-Red Brass. Valve shall be in compliance to the applicable sections of ASSE 1037.

Accessories

See Accessories Section of the Sloan catalog for details on these and other Flushometer variations.

*SaniGuard does not protect users or others against disease-causing bacteria.



Made In The
USA



Sloan BPW-1100 04-14
Copyright © 2014 SLOAN VALVE COMPANY

This space for Architect/Engineer approval

Job Name _____ Date _____

Model Specified _____ Quantity _____

Variations Specified _____

Customer/Wholesaler _____

Contractor _____

Architect _____

The information contained in this document is subject to change without notice.

SLOAN

SLOAN • 10500 SEYMOUR AVE. • FRANKLIN PARK, IL 60131

Ph: 1-800-9-VALVE-9 or 1-847-671-4300 • Fax: 1-800-447-8329 or 1-847-671-4380

www.sloanvalve.com