


SPX Hydraulic Technologies 5885 IIth Street Rockford, IL 61109-3699 USA **powerteam.com** Tech. Services: (800) 477-8326 Fax: (800) 765-8326 Order Entry: (800) 541-1418 Fax: (800) 288-7031

Parts List for:

9526 9556 9559

2-POSITION, 3-WAY --- SOLENOID CONTROLLED DIRECTIONAL VALVE

Max. Capacity: 10,000 PSI



Item	Part	No.	
No.	No.	Req'd	Description
1	12650	4	Soc. Hd. Cap Screw (#10-24 UNC x 1-1/2 Lg.; Torque to 35/40 in. lbs.)
2	203102	1	Lever (Upper)
3	17026	2	Dowel Pin (1/8 dia. x 5/8 Lg.)
4	203100	1	Threaded Pin
5	10890	4	Soc. Hd. Cap Screw (1/4-20 x 2" Lg.)
6	203106	1	Poppet
7	*10265	1	O-ring (5/16 x 3/16 x 1/16)
8	*15174	1	Backup Washer (5/16 x 3/16 x 3/64)
9	17033	1	Compression Spring (5/16 I.D. x 5/8 Lg.)
10	*15292	1	O-ring (9/16 x 7/16 x 1/16)
11	350004	1	Guide
12	250004	1	Special Jam Screw (Torque to 225/250 in. lbs.)
13	309231	1	Metering Valve
14	58003	1	Valve Body
15	11127	2	Pipe Plug (3/8 NPTF)
16	203104	1	Stem
17	*10264	1	O-ring (1/4 x 1/8 x 1/16)
18	12223	1	Ball (3/16 dia.)
19	203103	1	Lever (Lower)
20	203101	1	Pin
21	421452	1	Linkage Block
22	10138	1	Set Screw (1/4-20 UNC x 5/8 Lg.)
23	10199	1	Nut (1/4-20 UNC)
24	17027-1	1	Solenoid (115 V., 50/60 Hz.)
	17027-2	1	Solenoid (220 V., 50/60 Hz.)
	306560	1	Solenoid (24 V., 50/60 Hz.)
	PARTS 250014	INCLUD 1	ED BUT NOT SHOWN Trade Name Decal

Part numbers marked with an asterisk (*) are contained in Repair Kit No. 300489.

ADVANCE, HOLD, RETURN SPECIFICATIONS

This is a remote-mounted, solenoid-operated, 2-position, 3-way valve. The valve has "advance" and "return" positions.

Advance: By running pump with solenoid de-energized. (Pump flow enters and goes directly to the cylinder port.)

Hold: Work is held when pump is stopped with solenoid deenergized. (Oil is held at outlet check in pump and at


release poppet check in the valve.)

Return: Oil is directed back to tank by energizing the solenoid.

(Release poppet opens through a force multiplying

linkage.)

J.I.C. SYMBOL



Note: For leakproof operation this valve should be used with a check valve located in the pressure line from pump unit.

Refer to any operating instructions included with the product for detailed information about operation, disassembly, and preventive maintenance.

Items found in this parts list have been carefully tested and selected. **Therefore: Use only genuine Power Team replacement parts!**


Additional questions can be directed to one of our Technical Services Departments.


Parts List Form No. 100802


SECTION A-A SPECIFICATIONS



Note: Cap unused lead.







IMPORTANT:

Linkage Adjustment

- 1. Adjust pin #203100 (Item no. 4) to dim. "A".
- 2. Adjust set screw #10138 (Item no. 22) until upper lever #203102 (Item no. 2) is at dim. "B".
- 3. Lock in position with nut #10199 (Item no. 23).

Sheet No.	2 of 2
Rev. 4	Date: 15 July 2008