

3-POLE 70AMP. LOAD CENTER  
 30AMP. BREAKER 1-POLE  
 20AMP. BREAKER 1-POLE

LOOP FEED LUG  
 TERMINAL BAR

5-20R2GFI  
 20AMP.  
 GFI DUPLEX

R32U  
 30AMP.  
 RECEPTACLE

WIRE RANGE TABLE :

| CONNECTOR                                      | COPPER     |        | ALUMINUM   |        |
|------------------------------------------------|------------|--------|------------|--------|
|                                                | SOLID      | STRAND | SOLID      | STRAND |
| LINE                                           | 14-8       | 14-2   | 12-8       | 12-2   |
| LOAD                                           | 14-10      | 14-10  | ---        | ---    |
| NEUTRAL                                        | 14-8       | 14-2   | 12-8       | 12-2   |
| NEUTRAL                                        | 14-8       | 14-4   | 12-8       | 12-4   |
| EQUIP. GRND.                                   | 12-8       | 12-2   | 12-8       | 12-2   |
| POST LINE CONNECTORS<br>SUITABLE FOR LOOP FEED | #2-250 MCM |        | #2-250 MCM |        |
| EQUIP. GRND.                                   | 12-2       | 12-2   | 12-2       | 12-2   |

1-1/4" X 1/2"  
 MOUNTING HOLE (4X)

NOTES: PAD MOUNTED POST

AutoCad Generated

Dr. By: JDE Date: 3-20-08  
 Ck. By: Date:

MIDWEST ELECTRIC  
 PRODUCTS, INC.  
 Mankato, MN



Unless Otherwise Specified  
 Tolerances On:  
 3 Pl. Decimals ± .010  
 2 Pl. Decimals ± .030  
 Fractions ± 1/32  
 Angles ± 1/2°  
 Holes ± .003  
 Dimensions Are In Inches

\* = Critical To Quality  
 SCALE 1 : 1  
 SIZE A  
 SHEET 1 OF 1

TITLE: U041CB4L10  
 HEAD/ POST OUTLINE  
 DWG NO: 198B8603

SH28

Rev. CR R0815611 JE 3-20-08