

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 NEMA Premium Efficiency Three-Phase Product code : 11611199
Catalog # : 00158ET3E145T-W22

Frame : 143/5T	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation ¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight ² : 50.2 lb
Protection degree : IP55	Moment of inertia (J) : 0.1431 sq.ft.lb
Design : B	

Output [HP]	1.5	1.5	1.5	1.5
Poles	4	4	4	4
Frequency [Hz]	60	50	50	50
Rated voltage [V]	208-230/460	380	400	415
Rated current [A]	4.36-4.04/2.02	2.42	2.33	2.30
L. R. Amperes [A]	36.6-33.9/17.0	15.5	16.3	17.0
LRC [A]	8.4x(Code L)	6.4x(Code H)	7.0x(Code J)	7.4x(Code K)
No load current [A]	1.81-2.10/1.05	1.05	1.15	1.20
Rated speed [RPM]	1755	1440	1445	1450
Slip [%]	2.50	4.00	3.67	3.33
Rated torque [ft.lb]	4.43	5.40	5.38	5.36
Locked rotor torque [%]	250	180	200	220
Breakdown torque [%]	340	240	280	300
Service factor	1.25	1.25	1.25	1.25
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	25s (cold) 14s (hot)	25s (cold) 14s (hot)	25s (cold) 14s (hot)	25s (cold) 14s (hot)
Noise level ²	51.0 dB(A)	49.0 dB(A)	49.0 dB(A)	49.0 dB(A)
Efficiency (%)	25%	81.3	82.0	82.1
	50%	82.5	82.5	82.5
	75%	85.5	84.0	84.0
	100%	86.5	84.1	84.1
Power Factor	25%	0.36	0.42	0.38
	50%	0.60	0.67	0.63
	75%	0.70	0.76	0.74
	100%	0.79	0.82	0.81

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6205 ZZ	6204 ZZ	Max. traction : 117 lb
Sealing :	V'Ring	V'Ring	Max. compression : 167 lb
Lubrication interval :	-	-	
Lubricant amount :	-	-	
Lubricant type :	Mobil Polyrex EM		

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	24/01/2018			
		Page 1 / 1		Revision