

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 Tru-Metric IE3 Three-Phase Product code : 12490360
Catalog # : 15012ET3Y315L-W22

Frame : 315L	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : B3L(E)
Duty cycle : S1	Rotation ¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight ² : 3253 lb
Protection degree : IP55	Moment of inertia (J) : 264 sq.ft.lb
Design : N	

Output [HP]	200	200	200	200
Poles	6	6	6	6
Frequency [Hz]	60	50	50	50
Rated voltage [V]	460	380	400	415
Rated current [A]	240	282	271	264
L. R. Amperes [A]	1752	2002	1924	1874
LRC [A]	7.3	7.1	7.1	7.1
No load current [A]	105	103	110	116
Rated speed [RPM]	1190	990	990	990
Slip [%]	0.83	1.00	1.00	1.00
Rated torque [ft.lb]	871	1050	1050	1050
Locked rotor torque [%]	280	220	250	270
Breakdown torque [%]	300	250	280	300
Service factor	1.15	1.00	1.00	1.00
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	73s (cold) 41s (hot)	45s (cold) 25s (hot)	45s (cold) 25s (hot)	45s (cold) 25s (hot)
Noise level ²	71.0 dB(A)	68.0 dB(A)	68.0 dB(A)	68.0 dB(A)
Efficiency (%)	25%	95.3	95.7	95.4
	50%	95.4	95.8	95.7
	75%	95.8	96.1	96.1
	100%	95.8	96.1	96.3
Power Factor	25%	0.40	0.45	0.42
	50%	0.66	0.70	0.67
	75%	0.77	0.80	0.78
	100%	0.82	0.84	0.83

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6319 C3	6316 C3	Max. traction : 6009 lb
Sealing :	WSeal	WSeal	Max. compression : 9263 lb
Lubrication interval :	13000 h	16000 h	
Lubricant amount :	45 g	34 g	
Lubricant type :	Mobil Polyrex EM		

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	22/01/2018			
		Page 1 / 1		Revision