

# DATA SHEET

## Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 Super Premium Efficiency Three-Phase Product code : 12792146  
Catalog # : 00318EG3E182T-W22

Frame : 182/4T	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation <sup>1</sup> : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight <sup>2</sup> : 96.8 lb
Protection degree : IP55	Moment of inertia (J) : 0.4017 sq.ft.lb
Design : A	

Output [HP]	3	3	3	3
Poles	4	4	4	4
Frequency [Hz]	60	50	50	50
Rated voltage [V]	230/460	380	400	415
Rated current [A]	7.50/3.75	4.45	4.33	4.19
L. R. Amperes [A]	62.3/31.1	31.2	31.6	32.7
LRC [A]	8.3x(Code K)	7.0x(Code H)	7.3x(Code J)	7.8x(Code J)
No load current [A]	3.80/1.90	1.80	1.95	2.10
Rated speed [RPM]	1765	1455	1460	1465
Slip [%]	1.94	3.00	2.67	2.33
Rated torque [ft.lb]	8.81	10.7	10.6	10.6
Locked rotor torque [%]	227	190	220	240
Breakdown torque [%]	320	240	260	280
Service factor	1.25	1.15	1.15	1.15
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	64s (cold) 36s (hot)	54s (cold) 30s (hot)	54s (cold) 30s (hot)	54s (cold) 30s (hot)
Noise level <sup>2</sup>	56.0 dB(A)	56.0 dB(A)	56.0 dB(A)	56.0 dB(A)
Efficiency (%)	25%	85.2	88.2	89.3
	50%	87.5	88.5	89.5
	75%	88.5	89.5	90.2
	100%	91.0	89.5	90.2
Power Factor	25%	0.38	0.44	0.37
	50%	0.63	0.69	0.62
	75%	0.75	0.79	0.74
	100%	0.81	0.84	0.81

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6207 ZZ	6206 ZZ	Max. traction : 144 lb
Sealing :	V'Ring	V'Ring	Max. compression : 241 lb
Lubrication interval :	-	-	
Lubricant amount :	-	-	
Lubricant type :	Mobil Polyrex EM		

### Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	24/01/2018			

Page 1 / 1  
Revision