DATA SHEET

Three Phase Induction Motor - Squirrel Cage



0.79

Customer :

Product line : W21 Flameproof Motor NEMA

Premium Efficiency Three-Phase

Product code: 11341200

Catalog # : 00158XT3E145T

Frame : 145T Cooling method : IC411 - TEFC

Insulation class : F Mounting : F-1

Duty cycle : Cont.(S1) Rotation¹ : Both (CW and CCW)

Ambient temperature : 20°C to +40°C Starting method : Direct On Line

Ambient temperature : -20°C to +40°C Starting method : Direct On Line
Altitude : 1000 m.a.s.l. Approx. weight³ : 72.1 lb

Altitude : 1000 m.a.s.l. Approx. weight³ : 72.1 lb

Protection degree : IP55 Moment of inertia (J) : 0.1303 sq.ft.lk

| Protection degree | | Moment of ine | Moment of inertia (J) : 0.1303 sq.ft.lb | | | |
|--------------------------|----------------------------------|---|---|--|--|--|
| | : B | | | | | |
| Output [HP] | | 1.5 | 1.5 | 1.5 | | |
| | 4 | 4 | 4 | 4 | | |
| | 60 | 50 | 50 | 50 | | |
| | 208-230/460 | 380 | 400 | 415 | | |
| | 4.53-4.10/2.05 | 2.40 | 2.33 | 2.27 | | |
| | 40.4-36.5/18.2 | 15.8 | 16.8 | 17.5 | | |
| | 8.9x(Code L) | 6.6x(Code H) | 7.2x(Code J) | 7.7x(Code K) | | |
| | 2.28-2.64/1.32 | 1.32 | 1.43 | 1.49 | | |
| Rated speed [RPM] | | 1440 | 1450 | 1450 | | |
| Slip [%] | | 4.00 | 3.33 | 3.33 | | |
| Rated torque [ft.lb] | | 5.40 | 5.36 | 5.36 | | |
| Locked rotor torque [%] | | 200 | 229 | 250 | | |
| Breakdown torque [%] | | 260 | 290 | 320 | | |
| Service factor | | 1.00 | 1.00 | 1.00 | | |
| Temperature rise | | 80 K | 80 K | 80 K | | |
| Locked rotor time | | 27s (cold) 15s (hot) | 27s (cold) 15s (hot) | 27s (cold) 15s (hot) | | |
| Noise level ² | | 49.0 dB(A) | 49.0 dB(A) | 49.0 dB(A) | | |
| | 80.3 | 83.7 | 83.8 | 80.9 | | |
| | 81.5 | 84.0 | 84.0 | 82.5 | | |
| 75% | 85.5 | 84.0 | 84.0 | 84.0 | | |
| 100% | 86.5 | 84.0 | 84.0 | 85.5 | | |
| 25% | 0.32 | 0.38 | 0.34 | 0.32 | | |
| 50% | 0.58 | 0.66 | 0.62 | 0.58 | | |
| 75% | 0.70 | 0.77 | 0.74 | 0.71 | | |
| | 25% 50% 75% 100% 25% | : B 1.5 4 60 208-230/460 4.53-4.10/2.05 40.4-36.5/18.2 8.9x(Code L) 2.28-2.64/1.32 1760 2.22 4.42 e [%] 270 [%] 350 1.15 80 K 25s (cold) 14s (hot) 51.0 dB(A) 25% 80.3 50% 81.5 75% 85.5 100% 86.5 25% 0.32 50% 0.58 | : B 1.5 | : B 1.5 1.5 1.5 1.5 4 4 4 4 4 4 4 60 50 50 50 50 208-230/460 380 400 4.53-4.10/2.05 2.40 2.33 40.4-36.5/18.2 15.8 8.9x(Code L) 6.6x(Code H) 7.2x(Code J) 2.28-2.64/1.32 1.32 1.43 11 1760 1440 1450 2.22 4.00 3.33 4.42 5.40 5.36 e [%] 270 200 229 [%] 350 260 290 1.15 1.00 1.00 80 K 80 K 80 K 80 K 80 K 25s (cold) 14s (hot) 27s (cold) 15s (hot) 51.0 dB(A) 49.0 dB(A) 49.0 dB(A) 49.0 dB(A) 55% 80.3 83.7 83.8 50% 81.5 84.0 84.0 84.0 100% 86.5 84.0 84.0 84.0 100% 86.5 84.0 84.0 84.0 100% 86.5 84.0 84.0 84.0 9.56% 9.32 0.38 0.34 50% 0.58 | | |

<u>Drive end</u> <u>Non drive end</u> Foundation loads

0.83

Bearing type : 6205 2RS 6204 2RS | Max. traction : 115 lb Sealing : Oil Seal Lip Seal Max. compression : 187 lb

Lubrication interval : - - Lubricant amount : - -

0.78

Lubricant type : Mobil Polyrex EM

100%

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

0.81

| Rev. | Changes Summary | | Performed | Checked | Date |
|--------------|-----------------|--|-----------|---------|----------|
| | | | | | |
| Performed by | | | | | |
| Checked by | | | | Page | Revision |
| Date | 23/01/2018 | | | 1/2 | |

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



| Customer | |
|----------|--|
| | |

Thermal protection

| ID | Application | Туре | Quantity | Sensing Temperature | |
|----|-------------|----------------------|-----------|---------------------|--|
| 1 | Winding | Thermostat - 2 wires | 1 x Phase | 130 °C | |
| 2 | Winding | Thermostat - 2 wires | 1 x Phase | 155 °C | |

| Rev. | | Changes Summary | Performed | Checked | Date |
|--------------|------------|-----------------|-----------|---------|----------|
| | | | | | |
| Performed by | | | | | |
| Checked by | | | | Page | Revision |
| Date | 23/01/2018 | | | 2/2 | |