

# DATA SHEET

## Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W40 NEMA Premium Efficiency Three-Phase Product code : 14495055  
Catalog # : 02512OT3E324T-W40

Frame : 324T	Cooling method : IC01 - ODP
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation <sup>1</sup> : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight <sup>2</sup> : 453 lb
Protection degree : IP23	Moment of inertia (J) : 7.69 sq.ft.lb
Design : B	

Output [HP]	25	20	20	20
Poles	6	6	6	6
Frequency [Hz]	60	50	50	50
Rated voltage [V]	230/460	380	400	415
Rated current [A]	61.6/30.8	30.5	30.1	29.7
L. R. Amperes [A]	382/191	201	205	205
LRC [A]	6.2x(Code G)	6.6x(Code H)	6.8x(Code H)	6.9x(Code J)
No load current [A]	28.4/14.2	14.0	15.5	16.7
Rated speed [RPM]	1183	980	985	985
Slip [%]	1.42	2.00	1.50	1.50
Rated torque [ft.lb]	111	107	107	107
Locked rotor torque [%]	210	170	229	210
Breakdown torque [%]	250	250	290	310
Service factor	1.25	1.00	1.00	1.00
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	32s (cold) 18s (hot)	23s (cold) 13s (hot)	25s (cold) 14s (hot)	25s (cold) 14s (hot)
Noise level <sup>2</sup>	62.0 dB(A)			
Efficiency (%)	25%	91.0	90.6	90.9
	50%	91.7	90.8	91.0
	75%	92.4	91.2	91.2
	100%	93.0	91.2	91.2
Power Factor	25%	0.39	0.39	0.35
	50%	0.65	0.65	0.60
	75%	0.76	0.76	0.73
	100%	0.81	0.82	0.79

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6312 Z C3	6211 Z C3	Max. traction
Sealing :	Without	Without	Max. compression
	Bearing Seal	Bearing Seal	
Lubrication interval :	20000 h	20000 h	
Lubricant amount :	21 g	11 g	
Lubricant type :	Mobil Polyrex EM		

Notes  
USABLE @208V 68.1A SF 1.15 SFA 78.3A

This revision replaces and cancel the previous one, which must be eliminated.  
(1) Looking the motor from the shaft end.  
(2) Measured at 1m and with tolerance of +3dB(A).  
(3) Approximate weight subject to changes after manufacturing process.  
(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	11/04/2020			

Page 1 / 1  
Revision