DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 IEEE 841 NEMA Premium

Efficiency Three-Phase

Product code: 13337942

Catalog #: 15009ST3QIERB447T-W2

Frame : 445/7T Cooling method : IC411 - TEFC

Insulation class : F Mounting : F-1

Duty cycle : Cont.(S1) Rotation¹ : Both (CW and CCW)

Ambient temperature : -20°C to +40°C Starting method : Direct On Line

Altitude : 1000 m.a.s.l. Approx. weight³ : 2236 lb
Protection degree : IP55 Moment of inertia (J) : 125 sq.ft.lb
Design : B

Output [HP] 150 125 125 125 Poles 8 8 8 8 Frequency [Hz] 50 50 50 60 Rated voltage [V] 380 400 415 460 Rated current [A] 185 183 177 175 L. R. Amperes [A] 1025 1097 1138 1110 6.0x(Code G) 5.6x(Code F) 6.2x(Code G) 6.5x(Code H) LRC [A] No load current [A] 80.0 78.9 83.3 86.8 Rated speed [RPM] 890 740 740 740 1.33 Slip [%] 1.11 1.33 1.33 Rated torque [ft.lb] 873 875 875 875 100

Locked rotor torque [%]		190	1/0	170 200	
Breakdown torque	: [%]	210	200	229	250
Service factor		1.15	1.15	1.15	1.15
Temperature rise		80 K	80 K	80 K	80 K
Locked rotor time		27s (cold) 15s (hot)			
Noise level ²		63.0 dB(A)			
	25%	94.4	94.9	94.0	93.5
Efficiency (%)	50%	94.5	94.5	94.1	93.6
Elliciency (70)	75%	94.5	94.1	94.1	94.1
	100%	94.5	93.6	94.1	94.1
	25%	0.39	0.40	0.37	0.34
Power Factor	50%	0.64	0.65	0.61	0.57
I OWEI Facior	75%	0.74	0.75	0.72	0.69
	100%	0.79	0.80	0.78	0.76

<u>Drive end</u> <u>Non drive end</u> Foundation loads

Bearing type : NU-319 C3 6316 C3 Max. traction : 4794 lb Sealing : Inpro/Seal Inpro/Seal Max. compression : 7030 lb

Lubrication interval : 15000 h 20000 h Lubricant amount : 45 g 34 g Lubricant type : Mobil Polyrex EM

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.		Changes Summary		Performed	Checked	Date
Performed by						
Checked by					Page	Revision
Date	23/01/2018				1/1	