

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 NEMA Premium Efficiency Three-Phase Product code : 12445969
Catalog # : 00718ET3E213TC-W22

Frame : 213/5TC	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation ¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight ² : 169 lb
Protection degree : IP55	Moment of inertia (J) : 1.34 sq.ft.lb
Design : B	

Output [HP]	7.5	7.5	7.5	7.5
Poles	4	4	4	4
Frequency [Hz]	60	50	50	50
Rated voltage [V]	208-230/460	380	400	415
Rated current [A]	19.9-18.4/9.18	11.0	10.5	10.3
L. R. Amperes [A]	141-130/65.2	61.6	65.1	69.0
LRC [A]	7.1x(Code H)	5.6x(Code F)	6.2x(Code G)	6.7x(Code H)
No load current [A]	7.59-8.80/4.40	4.00	4.30	4.55
Rated speed [RPM]	1765	1455	1460	1460
Slip [%]	1.94	3.00	2.67	2.67
Rated torque [ft.lb]	22.0	26.7	26.6	26.6
Locked rotor torque [%]	220	170	190	210
Breakdown torque [%]	310	240	270	290
Service factor	1.25	1.25	1.25	1.25
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	36s (cold) 20s (hot)	27s (cold) 15s (hot)	27s (cold) 15s (hot)	27s (cold) 15s (hot)
Noise level ²	58.0 dB(A)	56.0 dB(A)	56.0 dB(A)	56.0 dB(A)
Efficiency (%)	25%	88.6	89.2	89.2
	50%	89.5	89.5	89.5
	75%	91.0	89.5	90.2
	100%	91.7	89.6	90.2
Power Factor	25%	0.40	0.47	0.43
	50%	0.66	0.72	0.69
	75%	0.76	0.81	0.78
	100%	0.82	0.85	0.84

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6308 ZZ	6207 ZZ	Max. traction : 357 lb
Sealing :	V'Ring	V'Ring	Max. compression : 526 lb
Lubrication interval :	-	-	
Lubricant amount :	-	-	
Lubricant type :	Mobil Polyrex EM		

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	24/01/2018			
		Page 1 / 1		Revision