

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 NEMA Premium Efficiency Three-Phase Product code : 11723868
Catalog # : 00118ET3E143T-W22

Frame : 143/5T	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation ¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight ² : 45.0 lb
Protection degree : IP55	Moment of inertia (J) : 0.1172 sq.ft.lb
Design : B	

Output HP	1	1	1	1
Poles	4	4	4	4
Frequency [Hz]	60	50	50	50
Rated voltage [V]	208-230/460	380	400	415
Rated current (A)	3.07-2.94/1.47	1.71	1.65	1.63
L. R. Amperes (A)	25.8-24.7/12.3	10.9	11.5	12.1
LRC (A)	8.4x(Code L)	6.4x(Code J)	7.0x(Code K)	7.4x(Code K)
No load current (A)	0.940-1.88/0.940	0.930	1.00	1.08
Rated speed [RPM]	1760	1450	1455	1455
Slip [%]	2.22	3.33	3.00	3.00
Rated torque	2.94	3.57	3.56	3.56
Locked rotor torque [%]	320	220	240	260
Breakdown torque [%]	350	250	290	310
Service factor	1.25	1.25	1.25	1.25
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	32s (cold) 18s (hot)	32s (cold) 18s (hot)	32s (cold) 18s (hot)	32s (cold) 18s (hot)
Noise level ²	51.0 dB(A)	49.0 dB(A)	49.0 dB(A)	49.0 dB(A)
Efficiency (%)	25%	78.4	79.6	78.4
	50%	80.0	80.0	80.0
	75%	84.0	82.5	82.5
	100%	85.5	82.5	84.0
Power Factor	25%	0.31	0.36	0.33
	50%	0.55	0.62	0.58
	75%	0.68	0.74	0.71
	100%	0.75	0.81	0.78

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6205 ZZ	6204 ZZ	Max. traction : 75 lb
Sealing :	V'Ring	V'Ring	Max. compression : 120 lb
Lubrication interval :	-	-	
Lubricant amount :	-	-	
Lubricant type :	Mobil Polyrex EM		

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	30/08/2017			

Page 1 / 1
Revision