

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 NEMA Premium Efficiency Three-Phase Product code : 11441933
Catalog # : 00212ET3E184T-W22

Frame : 182/4T	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation ¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight ² : 97.0 lb
Protection degree : IP55	Moment of inertia (J) : 0.6210 sq.ft.lb
Design : B	

Output [HP]	2	2	2	2
Poles	6	6	6	6
Frequency [Hz]	60	50	50	50
Rated voltage [V]	208-230/460	380	400	415
Rated current [A]	7.13-6.44/3.22	3.66	3.61	3.58
L. R. Amperes [A]	53.5-48.3/24.2	22.0	24.2	25.4
LRC [A]	7.5x(Code L)	6.0x(Code J)	6.7x(Code K)	7.1x(Code L)
No load current [A]	3.28-3.80/1.90	1.90	2.05	2.15
Rated speed [RPM]	1170	960	965	965
Slip [%]	2.50	4.00	3.50	3.50
Rated torque [ft.lb]	8.86	10.8	10.7	10.7
Locked rotor torque [%]	300	229	280	310
Breakdown torque [%]	350	260	310	340
Service factor	1.25	1.00	1.00	1.00
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	55s (cold) 31s (hot)	36s (cold) 20s (hot)	36s (cold) 20s (hot)	36s (cold) 20s (hot)
Noise level ²	52.0 dB(A)	52.0 dB(A)	52.0 dB(A)	52.0 dB(A)
Efficiency (%)	25%	85.4	84.8	84.2
	50%	86.5	85.5	85.0
	75%	87.5	86.0	86.5
	100%	88.5	86.5	87.0
Power Factor	25%	0.26	0.31	0.26
	50%	0.46	0.53	0.46
	75%	0.58	0.65	0.59
	100%	0.66	0.72	0.69

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6207 ZZ	6206 ZZ	Max. traction : 188 lb
Sealing :	V'Ring	V'Ring	Max. compression : 285 lb
Lubrication interval :	-	-	
Lubricant amount :	-	-	
Lubricant type :	Mobil Polyrex EM		

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	27/01/2018			

Page 1 / 1
Revision