

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 NEMA Premium Efficiency Three-Phase Product code : 12445719
Catalog # : 00209ET3E213T-W22

Frame : 213/5T	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation ¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight ² : 161 lb
Protection degree : IP55	Moment of inertia (J) : 1.79 sq.ft.lb
Design : B	

Output [HP]	2	2	2	2
Poles	8	8	8	8
Frequency [Hz]	60	50	50	50
Rated voltage [V]	208-230/460	380	400	415
Rated current [A]	7.49-6.78/3.39	3.91	3.80	3.78
L. R. Amperes [A]	56.9-51.5/25.7	29.7	28.9	28.7
LRC [A]	7.6x(Code M)	7.6x(Code L)	7.6x(Code M)	7.6x(Code M)
No load current [A]	3.97-4.60/2.30	2.30	2.42	2.54
Rated speed [RPM]	875	715	720	720
Slip [%]	2.78	4.67	4.00	4.00
Rated torque [ft.lb]	11.8	14.5	14.4	14.4
Locked rotor torque [%]	240	190	229	270
Breakdown torque [%]	290	210	250	280
Service factor	1.25	1.00	1.00	1.00
Temperature rise	80 K	80 K	80 K	80 K
Locked rotor time	70s (cold) 39s (hot)	70s (cold) 39s (hot)	70s (cold) 39s (hot)	70s (cold) 39s (hot)
Noise level ²	52.0 dB(A)	48.0 dB(A)	48.0 dB(A)	48.0 dB(A)
Efficiency (%)	25%	81.0	81.2	81.2
	50%	82.5	81.5	81.5
	75%	84.0	82.0	82.5
	100%	85.5	82.0	82.5
Power Factor	25%	0.24	0.29	0.25
	50%	0.45	0.52	0.46
	75%	0.55	0.62	0.56
	100%	0.65	0.71	0.67

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6308 ZZ	6207 ZZ	Max. traction : 149 lb
Sealing :	V'Ring	V'Ring	Max. compression : 311 lb
Lubrication interval :	-	-	
Lubricant amount :	-	-	
Lubricant type :	Mobil Polyrex EM		

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	27/01/2018			

Page 1 / 1
Revision