## **DATA SHEET**

## Three Phase Induction Motor - Squirrel Cage



Customer Product line : Rolled Steel JP Pump NEMA Product code: 13367844 Premium Efficiency Three-Phase 01018OT3E215JP-SG Catalog #: Frame : 213/5JP Cooling method : IC01 - ODP Insulation class Mounting : F-1 Duty cycle : Cont.(S1) Rotation<sup>1</sup> : Both (CW and CCW) Ambient temperature : -20°C to +40°C Starting method : Direct On Line Altitude : 1000 m.a.s.l. Approx. weight<sup>3</sup> : 134 lb : 1.30 sq.ft.lb Design : B Moment of inertia (J) Output [HP] 10 10 10 Poles 4 4 50 Frequency [Hz] 60 50 220/415 Rated voltage [V] 208-230/460 190/380 Rated current [A] 27.4-24.8/12.4 29.8/14.9 26.4/14.0 L. R. Amperes [A] 192-174/86.8 191/95.4 201/106 LRC [A] 7.0x(Code H) 6.4x(Code G) 7.6x(Code J) No load current [A] 10.3-12.0/5.99 11.8/5.89 13.1/6.93 Rated speed [RPM] 1770 1460 1470 Slip [%] 1.67 2.67 2.00 Rated torque [ft.lb] 29.3 35.5 35.2 Locked rotor torque [%] 250 200 250 Breakdown torque [%] 350 250 300 Service factor 1.15 1.15 1.15 Temperature rise 80 K 80 K 80 K 0s (cold) 0s (hot) Locked rotor time 25s (cold) 14s (hot) 0s (cold) 0s (hot) Noise level<sup>2</sup> 59.0 dB(A) 56.0 dB(A) 56.0 dB(A) 25% 89.4 91.4 89.5 50% 90.2 90.1 89.1 Efficiency (%) 75% 91.0 89.7 89.7 100% 91.7 88.1 89.0 25% 0.38 0.45 0.38 50% 0.64 0.72 0.64 Power Factor 75% 0.77 0.82 0.77 100% 0.83 0.84 0.87 Drive end Non drive end Foundation loads Bearing type 6209 ZZ 6206 ZZ : 538 lb Max. traction Sealing Without Without Max. compression : 671 lb Bearing Seal Bearing Seal Lubrication interval Lubricant amount

Lubricant type Mobil Polyrex EM

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.

(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary		Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	22/01/2018			1/1	