

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 Close Coupled Pump JM
NEMA Premium Efficiency Three-Phase
Product code : 12941830
Catalog # : 01012ET3E256JM-W22

Frame : 254/6JM	Cooling method : IC411 - TEFC
Insulation class : F	Mounting : F-1
Duty cycle : Cont.(S1)	Rotation ¹ : Both (CW and CCW)
Ambient temperature : -20°C to +40°C	Starting method : Direct On Line
Altitude : 1000 m.a.s.l.	Approx. weight ² : 290 lb
Protection degree : IP55	Moment of inertia (J) : 4.43 sq.ft.lb
Design : B	

Output [HP]	10	10	10	10
Poles	6	6	6	6
Frequency [Hz]	60	50	50	50
Rated voltage [V]	208-230/460	380	400	415
Rated current [A]	28.5-26.6/13.3	15.4	14.8	14.4
L. R. Amperes [A]	185-173/86.5	78.5	84.4	87.8
LRC [A]	6.5x(Code H)	5.1x(Code F)	5.7x(Code G)	6.1x(Code H)
No load current [A]	10.3-12.0/6.00	4.90	6.30	6.60
Rated speed [RPM]	1175	965	970	975
Slip [%]	2.08	3.50	3.00	2.50
Rated torque [ft.lb]	44.1	53.7	53.4	53.1
Locked rotor torque [%]	229	170	200	220
Breakdown torque [%]	280	220	240	260
Service factor	1.25	1.00	1.15	1.15
Temperature rise	80 K	105 K	105 K	80 K
Locked rotor time	46s (cold) 26s (hot)	39s (cold) 22s (hot)	39s (cold) 22s (hot)	39s (cold) 22s (hot)
Noise level ²	59.0 dB(A)	56.0 dB(A)	56.0 dB(A)	56.0 dB(A)
Efficiency (%)	25%			
	50%	90.2	90.2	89.5
	75%	91.0	89.5	90.2
	100%	91.0	89.1	89.5
Power Factor	25%			
	50%	0.63	0.70	0.66
	75%	0.74	0.79	0.77
	100%	0.78	0.83	0.82

	<u>Drive end</u>	<u>Non drive end</u>	Foundation loads
Bearing type :	6309 C3	6209 C3	Max. traction : 526 lb
Sealing :	V'Ring	V'Ring	Max. compression : 817 lb
Lubrication interval :	20000 h	20000 h	
Lubricant amount :	13 g	9 g	
Lubricant type :	Mobil Polyrex EM		

Notes

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	22/01/2018			

Page 1 / 1
Revision