DATA SHEET

Three Phase Induction Motor - Squirrel Cage

:



Customer

Product line		: Rolled Steel JP Pump NEMA		12682733
		Premium Efficiency Three-Pha	Catalog # :	00212OT3E184JP-S
Frame		: 182/4JP	Cooling method	: IC01 - ODP
Insulation class		:F	Mounting	: F-1
Duty cycle		: Cont.(S1)	Rotation ¹	: Both (CW and CCW)
Ambient temperature		: -20°C to +40°C	Starting method	: Direct On Line
Altitude		: 1000 m.a.s.l.	Approx. weight ³	: 0.0 lb
Design		: B	Moment of inertia (J)	: 0.2800 sq.ft.lb
Output [HP]		2	2	2
Poles		6	6	6
Frequency [Hz]		60	50	50
Rated voltage [V]		208-230/460	190/380	220/415
Rated current [A]		6.52-5.90/2.95	6.96/3.48	6.34/3.36
L. R. Amperes [A]		43.0-38.9/19.5	35.5/17.7	38.7/20.5
LRC [A]		6.6x(Code J)	5.1x(Code G)	6.1x(Code J)
No load current [A]		2.95-3.42/1.71	3.37/1.69	3.75/1.99
Rated speed [RPM]		1165	945	955
Slip [%]		2.92	5.50	4.50
Rated torque [ft.lb		8.89	11.0	10.8
Locked rotor torqu		200	160	210
Breakdown torque [%]		300	220	270
Service factor		1.15	1.00	1.00
Temperature rise		80 K	105 K	80 K
Locked rotor time		59s (cold) 33s (hot)	0s (cold) 0s (hot)	0s (cold) 0s (hot)
Noise level ²		52.0 dB(A)	50.0 dB(A)	50.0 dB(A)
Efficiency (%)	25%			
	50%	85.5	84.8	83.0
	75%	86.5	84.9	84.6
	100%	87.5	83.0	84.0
	25%			
Power Factor	25% 50%	0.53	0.61	0.53
Power Factor	25% 50% 75%	0.66	0.73	0.66
Power Factor Notes	25% 50%			
Notes This revision repl	25% 50% 75% 100%	0.66	0.73 0.79 These are average values I	0.66 0.74
Notes This revision repl must be eliminate (1) Looking the n	25% 50% 75% 100%	0.66 0.73	0.73 0.79 These are average values I	0.66 0.74
Notes This revision repl must be eliminate (1) Looking the n (2) Measured at (4) At 100% of fu	25% 50% 75% 100%	0.66 0.73	0.73 0.79 These are average values I power supply, subject to the MG-1.	based on tests with sinusoidal
Notes This revision repl must be eliminate (1) Looking the n (2) Measured at (4) At 100% of fu Rev.	25% 50% 75% 100%	0.66 0.73	0.73 0.79 These are average values I power supply, subject to the MG-1.	based on tests with sinusoidal
Notes This revision repl must be eliminate (1) Looking the n (2) Measured at (4) At 100% of fu	25% 50% 75% 100%	0.66 0.73	0.73 0.79 These are average values I power supply, subject to the MG-1.	based on tests with sinusoidal

This document is exclusive property of WEG S/A. Reprinting is not allowed without written authorization of WEG S/A. Subject to change without notice