# **Cable Connectors**

## For Armored Cable & Flexible Metal Conduit

## Type AC

## 45° Angle Squeeze Connectors

#### lise

To ground and secure Armored Cable and Flexible Metal Conduit to boxes and enclosures.

#### Features:

- · Male hubs NPS.
- · Provided with center stop.
- · Available with insulated throats.
- · Furnished with locknuts
- Also suitable for NM and SE cable

#### Material/Finish:

Malleable Iron/Zinc Electroplated

## **Third Party Certification:**



UL Listed: E-11852


UL Listed for armored cable and flexible steel conduit.

UL Listed flexible metal conduit fittings are suitable for use in Hazardous Location under NEC 501-4(b) Class I Div. II, and suitable as a grounding means under NEC 350-5.




CSA Certified: 9795.

CSA Certified for armored cable.







Type AC-50

Trade Size (inches)	Catalog Number	Insulated Throat Catalog Number	Body Length	Dimensio Thread Length	ns in Inch Max. Width	es Flex. Opening
<sup>3</sup> / <sub>8</sub> (¹/ <sub>2</sub> KO) <sup>1</sup> / <sub>2</sub> <sup>3</sup> / <sub>4</sub>	AC-38	AC-38T	1 <sup>3</sup> / <sub>8</sub>	7/ <sub>16</sub>	1 <sup>1</sup> / <sub>4</sub>	17/ <sub>32</sub> - 39/ <sub>64</sub>
	AC-50	AC-50T	1 <sup>15</sup> / <sub>16</sub>	7/ <sub>16</sub>	1 <sup>11</sup> / <sub>16</sub>	25/ <sub>32</sub> - 15/ <sub>16</sub>
	AC-75	AC-75T	2 <sup>1</sup> / <sub>8</sub>	1/ <sub>2</sub>	1 <sup>3</sup> / <sub>4</sub>	29/ <sub>32</sub> - <b>1</b> <sup>1</sup> / <sub>16</sub>

## **Applicable Third Party Standards:**

UL Standard: 514B CSA Standard C22.2 No. 18 Fed. Spec: W-F-406E

NEMA: FB-1

Туре	25-38C
Duplex	<b>Connector</b>

#### Use:

To ground and secure two Armored Cables to boxes and enclosures.

#### Features:

- For armored cable 14/2 to 10/2 or combination of sizes
- Furnished with locknuts.
- Male hubs-NPS


## Material/Finish:


Malleable Iron/Zinc Plated

### Third Party Certification:



UL Listed: E-11852 UL Listed flexible metal conduit fittings are suitable for use in Hazardous Locations under NEC 501-4(b) Class I Div. II, and suitable as a grounding means under NEC 350-5.





Type 25-38C



CSA Certified: 9795

# **Applicable Third Party Standards:**

UL Standard: 514B CSA Standard C22.2 No. 18 Fed. Spec: W-F-406E NEMA: FB-1