



355 Concrete Insert – 3550000EG



- Structural attachment in all grades of concrete
- Knockout keeps interior empty during pour
- Allows for horizontal rod adjustment up to 1-1/4"
- 355N Insert Nut required for UL Listing and FM Approval
- Conforms with Federal Specification WW-H-171 (Type 19), Manufacturers Standardization Society ANSI®/MSS-SP-58 (Type 18)



Part Number	3550000EG
Material	Steel
Finish	Electrogalvanized
Rod Size (RS)	3/8" 1/2" 5/8" 3/4" 7/8"
A	1 5/8"
B	3 9/16"
C	3"
Pipe Size	10" Max
Static Load (F)	1,200 lb
Standard Packaging Quantity	150 pc
UPC	78285635096
UNSPSC	31162101
Certifications	cULus FM

Rod should be threaded through the nut until it tightens against the top of the insert.

For installation, place knockout side down on concrete form and nail in place. Wire 12" piece of #4 reinforcing rod on both sides. After concrete pour, knockout can be removed with a screwdriver.

cULus® Listed for 3/8" rod size up to 4" pipe and 1/2", 5/8" and 3/4" rod sizes up to 6" pipe.

FM® Approved for 3/8", 1/2", 5/8", and 3/4" rod sizes up to 8" pipe.

Install in accordance with applicable code.

ANSI is a registered trademark of American National Standards Institute. FM is a registered certification mark of FM Approvals LLC, LTD. UL, UR, cUL, cUR, cULus and cURus are registered certification marks of UL LLC.

WARNING

ERICO products shall be installed and used only as indicated in ERICO's product instruction sheets and training materials. Instruction sheets are available at www.erico.com and from your ERICO customer service representative. Improper installation, misuse, misapplication or other failure to completely follow ERICO's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death.

Copyright © 2014 ERICO International Corporation. All rights reserved.

CADDY, CADWELD, CRITEC, ERICO, ERIFLEX, ERITECH, and LENTON are registered trademarks of ERICO International Corporation.

