


SAFETY PRECAUTIONS:

- TO REDUCE THE RISK OF ELECTRICAL SHOCK, FIRE, OR INJURY TO PERSONS; READ AND FOLLOW ALL WARNINGS AND INSTALLATION INSTRUCTIONS BEFORE INSTALLING. ALL INSTALLATION SHOULD BE PERFORMED BY A OUALIFIED ELECTRICIAN.
- RISK OF ELECTRIC SHOCK.
- · RISK OF FIRE.
- FOR YOUR SAFETY, WHILE PERFORMING INSTALLATIONS DESCRIBED, GLOVES, SAFETY GLASSES OR GOOGLES SHOULD BE WORN.
- INSTALL THIS KIT ONLY IN THE LUMINAIRE WITH THE CONSTRUCTION FEATURES AND DIMENSIONS SHOWN IN THE PHOTOGRAPHS AND/OR DRAWINGS.
- DO NOT MAKE OR ALTER ANY OPEN HOLES IN AN ENCLOSURE OF WIRING OR ELECTRICAL COMPONENTS DURING KIT INSTALLATION.
- TO PREVENT WIRING DAMAGE OR ABRASION, DO NOT EXPOSE WIRING TO EDGES OF SHEET METAL OR OTHER SHARP OBJECTS.
- DO NOT ALTER, RELOCATE, OR REMOVE WIRING, LAMPHOLDERS, POWER SUPPLY, OR ANY OTHER ELECTRICAL COMPONENT.
- MIN 167°F (75°C) SUPPLY.
- SUITABLE FOR OPERATION IN AMBIENT NOT EXCEEDING 122°F (50°C)
- THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.
- FOR DRY LOCATIONS ONLY.



- 1. CONNECT THE LAMP SHEATH WIRE WITH THE EXTERNAL POWER SUPPLY WIRE AND CONNECT IT ACCORDING TO THE DIAGRAM.
- 2. THE LENGTH OF THE SHEATH STRIPPING IS SUGGESTED AS SHOWN ON THE UPPER RIGHT.

WARNING:

NOTE THE L IS A BLACK CONDUCTOR, N IS A WHITE CONDUCTOR, AND THE GROUND IS A GREEN CONDUCTOR. POWER SUPPLY SHOULD NT BE CONNECT DURING OPERATION.

INSTALLATION:

- 1. REMOVE THE LED FIXTURE, ENSURE IT IS INTACT, AND REMOVE THE DIFFUSER FOR INSTALLATION.
- 2. ATTACH THE HOUSING TO THE CEILING WITH THE SCREWS AND THE EXPANSION BOLT.
- 3. CONNECT POWER WITH THE DRIVER. FOLLOW THE WIRING DIAGRAM AND MAKE SURE THE POWER SUPPLY IS DISCONNECTED BEFORE CONNECTING.
- 4. ADJUST THE WATTAGE AND CCT WITH THE SWITCH. (If the fixture is single wattage, please skip step#4)
- 5. INSTALL DIFFUSER BACK TO THE FIXTURE.

